

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Mary P. Burke, Secretary

July 23, 2004

TAKARA BELMONT KOKEN DIVISION LARRY HANDEL 1631 DR.MARTIN LUTHER KING DR. ST.LOUIS MO 63106

Re: Description: SINK, SHAMPOO Manufacturer: TAKARA BELMONT

Product Name: AQUA VIBRO Model Number(s): HS-803TSN Product File No: 20040182

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (5) and (6) based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2009.**

This alternate approval is contingent upon compliance with the following stipulation(s):

- A reduced pressure principle backflow preventer (ASSE 1013 or CAN/CSA B64.4) or air-gap must be installed on the water supply pipes serving this product.
- Approval is issued for this product because the design of the fixture tail piece meets the intent of s. Comm 84.30 (5) and (6), Wis. Adm. Code. The intent of the code is met since the fixture tail piece provides an acceptable inner wall surface for the waste.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wi.gov

SBD-10564-E (N.10/97) File Ref: 04018202.DOC